

DECLARATION OF CONFORMITY

Manufacturer: SATEL Sp. z o.o.
ul. Budowlanych 66
80-298 Gdańsk
tel. (+48 58) 320-94-00
fax. (+48 58) 320-94-01

declare under sole responsibility that

product: DB-100 - conventional mounting base for point fire detectors

Product description: The DB-100 base is used to connect the following detectors by SATEL: DMP-100, DRP-100 and DCP-100 to the detection line of the CSP-104 / CSP-108 / CSP-204 / CSP-208 conventional fire alarm control panel. The base can also be used to connect the conventional detectors to the MLB-400 side line module. The MLB-400 module is designed to operate in the detection line of the ACSP-402 addressable fire alarm control panel.

meet the essential requirements of the following EU Directives:

EMC: 2014/30/EU



Following harmonized standards have been applied for conformity assessment

EMC/Immunity EN 50130-4:2011, EN IEC 61000-6-1:2019

EMC/Emissions EN 55032:2015, EN IEC 61000-6-3:2021, EN IEC 61000-3-2:2019

Gdańsk, Poland, 07.05.2024

A handwritten signature in blue ink, appearing to read 'Mikołaj Liskin'.

Mikołaj LISKIN
Head of Research Department